

**NASSAU COUNTY DEPARTMENT OF PUBLIC WORKS
DIVISION OF ENGINEERING – CIVIL/SITE ENGINEERING UNIT**

239f # _____

Date _____

To: Bldg. Dept. Mgr.: Town of _____, or Village of _____

Location of Property: _____

The plan submitted for the above location under Section 239f of the General Municipal Law, is returned herewith, without approval, for the following reasons (circled/underlined/Bolded or noted below):

HIGHWAY DESIGN REVIEW

1. Show proposed grading of lot relative to street and abutting terrain. Proposed spot elevations on PL and/or contour lines are required. Showing flow arrows in place of elevations is not sufficient.
2. Show existing adjacent roadway features (pavement, curb, sidewalk, elevations, utilities, etc.).
3. Show proposed utility connections (water, gas, sewer, electric, etc.) Show limit of restoration on plan.
4. Supply Pavement Restoration detail: (For use in Nassau County ROW)
Full depth sawcut, 2' from curb, varies for utilities.
1" Asphalt Concrete 1A top (Item 36DRA)
8" Asphalt Concrete Dense Base (Item 22C-2)
5. A dedication of _____ feet across the front of the parcel will be required. Details relative to that submission are attached.
6. Gradient of project site approaching County road is not acceptable. A high point must be created at the R.O.W. line and pitched from high point to the road and on-site drainage. Provide grades at/on PL and curb line. Trench Drains on the PL are not permitted. (Recommend 10' between trench drain and PL.)
7. Show distance from the corner of subject parcel to nearest intersection.
8. Add a north arrow to show orientation of parcel.
9. add as Note: All work within the Nassau County Right-of-Way shall conform to 2009 County of Nassau Department of Public Works Standard Specifications and Detail Sheets for Civil Engineering and Site Development Construction.
10. _____
11. _____
12. _____
13. _____
14. _____
15. _____

William Bottenhofer
Civil Engineer III, (516) 571-6916
1194 Prospect Ave., Westbury, N.Y. 11590-2723